

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 01/2024-25/HR

Dated: 11.04.25

It is certified that an inspection team headed by Sheet Kumar Singh

(Name of Officers with designation) from Asst. Supt. Officer PHED

inspected the Deep Academic Height will, Ganapatpur Post Strullia, Azamgarh UP

(Name & Address of the school) on 11.04.2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. WS09042025-0191 dated 09.04.2025

of Geo green Testing Laboratory (PHED Lab) certified that

the DEEP ACADEMIC HEIGHTS (Name of school) has safe drinking water

will. Ganapatpur Post Strullia Dist Azamgarh UP

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till one yrs

Signature with Seal: सहायक अभियुक्त (खाद्य)-III

Name अभिहित अधिकारी

Designation असम एवं औषधि प्रशासन

Name & Address of the Office / Department जनपद आजमगढ़

To DEEP ACADEMIC HEIGHTS

(Name & Address of the Institution) will. Ganapatpur Post Strullia Dist - Azamgarh

UP - 223223

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

शीत कुमार सिंह
खाद्य सुरक्षा अधिकारी
जनपद-आजमगढ़

GEOGREEN TESTING LABORATORY

AN ISO 9001:2015, OHSAS : 2007 Certified Laboratory

Laboratory : C 1/20, Viraj Khand, Gomti Nagar Lucknow - 226010 (U.P.)

Phone : +91 9415215163, 9161202020 Email : geogreen.tl@gmail.com

Website : www.geogreen.in

TEST REPORT

(Water Sample Analysis)

Format No. GTL/SF/50

Sample Code No.	GTL/WS/0191	Report No.	WS09042025-0191
Sample Code Given By Client	None	Issue Date	09/04/2025
Sample Drawn by	Client	Condition of the Sample	Sealed
Sample Drawn on	04/04/2025	Nature of Sample	Drinking Water
Sample Received on	05/04/2025	Test Duration	05/04/2025-09/04/2025
Sampling Location	At Canteen	Sample	2 liter
Client's Name & Address	M/s Deep Academic Heights Village Ganpatpur, Post- Atrauliya, Azamgarh, Uttar Pradesh-223223		

S. No.	Parameter Tested	Units	Result	Test Protocol Second Revision
1.	Color	Hazen	<5.0	APHA 2120 C,
2.	pH Value	-	7.04	APHA 4500- H ⁺ ,B
3.	Turbidity	NTU	Nil	APHA 2130 B
4.	Electrical Conductivity	µs/cm	653.4	APHA 2510 B
5.	Total Suspended Solids	mg/L	0.5	APHA 2540 D
6.	Total Dissolve Solid	mg/L	312.0	APHA 2540 C
7.	Total hardness as CaCO ₃	mg/L	284.0	APHA 2340-C
8.	Calcium as Ca	mg/L	88.17	APHA 3500-Ca B
9.	Magnesium as Mg	mg/L	14.47	APHA 3500 B
10.	Alkalinity as CaCO ₃	mg/L	292.0	APHA 2320 B
11.	Chlorides as CL ⁻	mg/L	20.99	APHA 4500 Cl ⁻ B
12.	Sulphate as So ₄ ²⁻	mg/L	19.5	APHA 4500 -So ₄ ²⁻ E
13.	Nitrate as NO ₃	mg/L	12.4	IS 3025 (Part 34)
14.	Iron as Fe	mg/L	Nil	APHA 3500 Fe B
15.	Fluoride as F ⁻	mg/L	0.33	APHA 4500 F ⁻ D
16.	Sodium as Na	mg/L	16.9	APHA 3500 Na B
17.	Potassium as K	mg/L	8.65	APHA 3500 K , B
18.	Residual Free Chlorine	mg/L	BDL	APHA 2350 B

Page-1/1

Statement of conformity: The submitted sample conforms to Indian standard (10500:2012)/ 24rd EDITION APHA 2022parameters at sr. no.1 to 16, Applying decision rule based on guard band with 95% confidence level.

NOTE:

1. The results given above are related to the tested sample, for various parameters, as observed at the time of sampling. The customer asked for the above tests only.
2. This test report will not be used for any publicity/ legal purpose.
3. The test samples will be disposed off after 15 days from the date of issue of test report, unless until specified by the customer.

End of Report

Prepared by

Ghulam

Review by

For Geogreen Testing Laboratory

Dr. Vijay Kumar Mishra
Quality Manager
(Authorized Signatory)

GEOGREEN TESTING LABORATORY

AN ISO 9001:2015, OHSAS : 2007 Certified Laboratory

Laboratory : C 1/20, Viraj Khand, Gomti Nagar Lucknow - 226010 (U.P.)

Phone : +91 9415215163, 9161202020 Email : geogreen.ll@gmail.com

Website : www.geogreen.in

TEST REPORT

(Water Sample Analysis)

Sample Code No.	GTL/WS/0191	Report No.	WS09042025-0191
Sample Code Given By Client	None	Issue Date	09/04/2025
Sample Drawn by	Client	Condition of the Sample	Sealed
Sample Drawn on	04/04/2025	Nature of Sample	Drinking Water
Sample Received on	05/04/2025	Test Duration	05/04/2025-09/04/2025
Sampling Location	At Canteen	Sample	2 liter
Client's Name & Address	M/s Deep Academic Heights Village Ganpatpur, Post- Atrauliya, Azamgarh, Uttar Pradesh-223223		

RESULTS

S. No.	Parameter Tested	Units	Result	Test Protocol
1.	Total Coliform	MPN/100ml	Absent	IS: 1622-1981
2.	Faecal Coliform	MPN/100ml	Absent	IS: 1622-1981

Page-1/1

- It is suitable for human consumption.
- The requirement mentioned here as per IS 10500: 2012 Drinking water specification
- Conformity statement: the sample complies to IS 10500: 2012 Drinking water specification with respect to above parameter tested.

End of Report

Prepared by

Shivam

Review by

[Signature]

For Geogreen Testing Laboratory

[Signature]
Dr. Vijay Kumar Mishra

Quality Manager
(Authorized Signatory)